

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-0368:101 Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Pottorff, *2824 N. Sylvania Ave., Fort Worth, TX 76111
Contact: Michael Beaver (817) 831 7038

DESIGN: Models VFD10, VFD10SS and VFD10TL and *VFD30. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, fire rating and UL label.

APPROVAL: Models VFD10, VFD10SS and VFD10TL are approved as 1-1/2 hour fire rated fire dampers. Model *VFD30 is approved as a 3-hour fire rated fire damper.

NOTE: Leakage rating not evaluated. Refer to CSFM Listing Category 3230 for leakage rated dampers.

*Rev. 06-15-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 15, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager